

VENT ONE 100/125 (THREE 100/125, FIVE 100, FRAME 100)







- 1. Vent housing (1x), e.g. Vent ONE
- 2. Vent cover (1x)
 *Suitability tested by the customer.
- 3. Vent bolts PZ, galvanised* (4x)
- 4. Expansion anchor F Nylon* (4x)




Ceiling installation at least 1.0 m distance from both sides of corner to vent edges. Wall installation at least 0.3 m distance from both sides of corner to vent edges. For exhaust air, no minimum distance.




Technical drawing All dimensions in mm



Technical drawing
All dimensions in mm




Technical drawing All dimensions in mm




Technical drawing All dimensions in mm






→ INSTALLATION INSTRUCTIONS FOR CEILING AND WALL


VENT ONE 100/125 VENT THREE 100/125 VENT FIVE 100 VENT FRAME 100



Shorten the vent pipe as necessary. Mark the screw holes (ø 4 mm) of the vent and drill pilot holes in the right size for your screws. Insert the expansion anchor. Appropriate for all solid materials. Suitablility tested by the customer.



Insert the vent housing into the vent pipe and fix it with a sealing tape (provided by the customer).




Screw the vent housing on the ceiling or wall. Suitability tested by the customer.



Snap the cover on (see instructions).

VENT ONE 100/125 (THREE 100/125, FIVE 100, FRAME 100)






Vent ONE 100/125 consisting of

- Vent housing with four slots
- 2. Vent cover with four flexible tabs.


Cover installation of vents THREE 100/125, FIVE 100 and FRAME 100 in the same way.




Lean the cover onto the vent.




Hold the cover firmly on the right and left side. With your index and middle fingers, guide the top vent cover tabs to the top slots and insert them. Hold the cover at a slight angle.



Insert the two flexible tabs into the free slots.




Keeping the cover at a slight angle and the tabs inserted, pull the cover toward the other two flexible tabs.



Now the cover is firmly in position.





→ COVER INSTALLATION

VENT ONE 100/125 VENT THREE 100/125 VENT FIVE 100 VENT FRAME 100